

## GROUND (FINISHED GRADE)

NO WORKING OBSTRUCTIONS ALLOWED IN SHADED AREA

----- INDICATES BOUNDARY OF AREA WHICH MUST BE KEPT CLEAR OF OBSTRUCTIONS.

## **NOTES:**

- 1. MAINTAIN A CLEARANCE AREA AROUND THE SOCKET AS SHOWN IN THE ILLUSTRATIONS.
- 2. THERE MUST BE AN 8" MIN HORIZONTAL AND A 9" MIN VERTICAL (ABOVE) CLEARANCE BETWEEN THE CENTER OF THE METER SOCKET AND ANY OBSTRUCTION. (NO OBSTRUCTIONS IN THE CLEARANCE AREA, SEE DRAWING ABOVE).
- 3. A LEVEL STANDING SPACE 36" L X 30" W, SHALL BE MAINTAINED IN FRONT OF THE METER SOCKET TO ALLOW FOR THE INSTALLATION, TESTING AND READING. (SEE SEC 3.1(a) (3) PAGE-4)
- 4. METERS SHALL BE LOCATED SO THAT THEY WILL NOT BE DAMAGED BY A SWINGING WINDOW, DOOR, OR GATE.
- 5. ON ANY OUT SWINGING DOOR, WINDOW, OR GATE OPENING, THE SURFACE OF THE WALL ON EITHER SIDE OF THAT DOOR, WINDOW, OR GATE FOR A DISTANCE EQUAL TO THE WIDTH OF THE DOOR, WINDOW, OR GATE IS UNACCEPTABLE AS A METER SPOT, UNLESS A SUITABLE PERMANENT DOOR, WINDOW, OR GATE STOP IS PROVIDED.

ENGR. TOO2		REV:	5	
SPEC. T003	CONSTRUCTION STANDARDS	DATE:	JUN 2013	
SMUD* SACRAMENTO MUNICIPAL UTILITY DISTRICT	REQUIRED MINIMUM CLEARANCES OF METER SOCKET FROM OBSTRUCTIONS	DRAWING REF	ERENCE#	A-1

